

# कार्यालय नगर पालिक निगम, जबलपुर


जबलपुर (म. प्र.)

क्रमांक सिटी/जल/२०/१९

दिनांक 13 0 MAY 2020

## प्रमाण पत्र

प्रमाणित किया जाता है कि डी.पी.एस. जूनियर स्कूल एकता चौक, विजय नगर विवेकानंद वार्ड जबलपुर में नगर निगम की पाइप लाइन नहीं है, शाला में स्वयं का नलकूप स्थापित है। स्कूल में छात्र/छात्राओं/शिक्षक-शिक्षिकाओं तथा अभिभावकों हेतु 10 नल से स्वच्छ पेयजल की पर्याप्त व्यवस्था है।

  
सहायक यंत्री  
जल प्रदाय विभाग  
नगर निगम, जबलपुर

**DISTRICT WATER TESTING LABORATORY**  
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

**WATER TESTING REPORT**

Report no. <u>12</u>	Date, <u>16-06-2020</u>	District..... <u>Jabalpur</u>
Ref. No. <u>-</u>	Date, <u>16-06-2020</u>	Village & Location
To, <u>The Delhi Public School Junior Rameshwaram Colony, Near Ekta Vihar, Vijay Nagar, Jabalpur (M.P.)</u>	Block	
Sample Collected by <u>George Jaeph</u>	3..	/
Date of collection <u>16-06-2020</u>		
Source <u>Water Cooler</u>	4..	
Date of receipt <u>16-06-2020</u>		
Date of Testing <u>16-06-2020</u>	5..	
Test conducted by <u>Poojima Soli</u>		

*Drinking Water Specifications As per BIS 10500:2012 (Second Revision)*

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	i	ii	iii	iv	v
--------	----------------	------	------------	---------------------	---	----	-----	----	---

**PHYSICAL-TEST**

1	Turbidity	NTU	1.0	5.0	4.7				
2	Colour	Pt. Cobalt			-				
3	Test & Odour	Unobjectionable	Unobjectionable		-				

**CHEMICAL-TEST**

4	pH	...	6.5 to 8.5	6.5 to 8.5	7.90				
5	Conductivity	µMhos/cm	..	..	1300				
6	Alkalinity	mg/l	200	600	280				
7	Chloride (As Cl)	mg/l	250	1000	315				
8	Nitrates	mg/l	45	45	0.88				
9	Total Hardness (As)	mg/l	200	600	570				
10	Total dissolved solid	mg/l	500	2000	844				
11	Iron (As Fe)	mg/l	0.3	1.0	0.10				
12	Manganese (As Mn)	mg/l	0.1	0.3	-				
13	Fluoride (As F)	mg/l	1.0	1.5	1.1				
14	Sulphates As So <sub>4</sub>	mg/l	200	400	148				
15	Residual Chlorine	mg/l	0.2	1.0	-				

**BAOTERIOLOGICAL-TEST**

16	Total Coliform	MPN/100ml	10	..	-				
17	E Coli or Thermo tolerant coliforms	MPN/100ml	..	..	-				

**REMARK:-** Water is fit for drinking purpose.

Note:- 1.As above result compared with BIS 10500:2012

- 2.Samples are not collected by us.
- 3.Not to be produced at court of law.
- 4.We do not take any responsibility for deviation in test result due to wrong collection of sample

  
**Asst. Engineer** 16-06-2020  
 Public Health Engg. Division  
 RHE Dn. Jabalpur  
 Jabalpur (M.P.)